



FAX
(925) 625-0169

IRONHOUSE SANITARY DISTRICT
450 Walnut Meadows Drive • P.O. Box 1105 • Oakley, CA 94561

Telephone
(925) 625-2279

IRONHOUSE SANITARY DISTRICT CONDITIONS OF PERMIT

- 1. Laterals:**

Direct connection into a sewer main is not allowed.

 - a. If installing a 4 inch lateral, use ABS pipe with a minimum slope of 1/4 inch per foot. This is the usual choice for a single family home.
 - b. If installing a 6 inch lateral, the connection must be into a manhole using ABS pipe with a minimum slope of 1%.

- 2. Cleanouts:**
 - a. First cleanout has to be within 18 inches of the foundation. It is recommended this cleanout be installed with a backup prevention device.
 - b. After 100 feet, another cleanout. After 135 degrees in accumulative fittings, another cleanout is required.

- 3. Bends in lateral:**
 - a. Within the first 5 feet of a cleanout, use 45 degree elbows with 1 foot separation.
 - b. Turns require 22 1/2 degree elbows with 1 foot separation.

- 4. Stubout connection:** To connect to a supplied stubout, use rubber couplings with transition (green) glue or transition bands.

- 5. Septic system:** Contact Contra Costa County Environmental Health Department for the procedure to shutdown the septic system. (925) 646-5225